


THERESA AXFORD
Superintendent of Schools



Members of the Board

District # 1
BOBBY HIGHSMITH

District # 2
ANDY GRIFFITHS
Vice-Chairman

District # 3
MINDY CONN

District #4
JOHN DICK
Chairman

District # 5
DR. SUE WOLTANSKI

Bid No: ITB 2022008

Name of Bid: Key Largo School Fire Alarm and Intercom System Replacement

Post Date: 3/30/2022

Notice Post Time: 4:00 p.m.

Q&A Response No: 2

Q1. Do they want all of the intercom speakers replaced?

A1. No, only those that are not working. Please provide a unit price per speaker for this item.

Q2. Will we be replacing the speaker systems in the Gym?

A2. No, only replace those that are not working. Please provide a unit price per speaker for this item.

Q3. Will there be double sided clocks in the halls?

A3. No

Q4. How many classrooms in each building?

A4. Please see table provided.

Q5. How many existing speakers in the hallways?

A5. Please see table provided.

Q6. How many speakers in the offices common areas? I want to make sure the information on the drawings are 100% accurate.

A6. Please see table provided.

Q7. Will there be double sided clocks in the halls?

A7. No

Building 10

Location	Wall mount Speaker/Clock	Ceiling Mounted Speaker	Callswitch	Common Area Speaker/clock	Resource Room	Existing Exterior Speakers
Building 10 perimeter						8
1st floor Hallway		16				
Media Center	1	11	1			
Pod 1-108	5		5	1		
Pod 1-116	5		5	1		
Pod 1-124	5		5	1	2	
Pod 1-133	5		5	1		1
Pod 1-141	5		5	1		2
2nd floor hallway		12				
Pod 1-216	4		4	1		1
Pod 1-224	5		5	1		1
Pod 1-233	5		5	1		2
Pod 1-241	5		5	1		2
3rd floor hallway		11				
Pod 1-316	4		4	1		2
Pod 1-324	5		5	1		1
Pod 1-333	5		5	1		1
Pod 1-341	5		5	1		1
TOTAL	64	50	64	13	16	8

Building 11

Location	Wall mount Speaker/Clock	Ceiling Mounted Speaker	Callswitch	Common Area Speaker/clock	Resource Room	Existing Exterior Speakers
Building 11 perimeter						3
Seating Area	6		2			
Kitchen	4					
Lounge	1		1			
Control room	1		1			
After Care	1					
Dressing Rooms	2					
TOTAL	15	0	4	0	0	3

Building 4

Location	Wall mount Speaker/Clock	Ceiling Mounted Speaker	Callswitch	Common Area Speaker/clock	Resource Room	Existing Exterior Speakers
Building 4 perimeter						2
Building 4 Interior	4	6	1			
TOTAL	4	6	1	0	0	2

Building 5

Location	Wall mount Speaker/Clock	Ceiling Mounted Speaker	Callswitch	Common Area Speaker/clock	Resource Room	Existing Exterior Speakers
Building 5 perimeter						4
Hallway Speakers		3				
Band Rm	1		1			
Guidance	3		1			
Art	1		1			
Video	2		2			
Health	1		1			
Tech	2		2			
CRT	1		1			
TOTAL	11	3	9	0	0	4

Building 6

Location	Wall mount Speaker/Clock	Ceiling Mounted Speaker	Callswitch	Common Area Speaker/clock	Resource Room	Existing Exterior Speakers
Building 6 perimeter						5
Hallway Speakers		2				
Music	1		1			
Day Care	1		1			
Gym	1		1			
Art	1		1			
IT	1					
Spanish	1		1			
AHEC	1		1			
ESE	13					
TOTAL	20	2	6	0	0	4

Building 8 & 9

Location	Wall mount Speaker/Clock	Ceiling Mounted Speaker	Callswitch	Common Area Speaker/clock	Resource Room	Existing Exterior Speakers
Building 8+9 perimiter						2
Gym	1	17	1			
Locker Rooms	2		2			
TOTAL	3	17	3	0	0	2