

THERESA AXFORD
Superintendent of Schools



Members of the Board

District #2
ANDY GRIFFITHS
Chairperson

District # 5
DR. SUE WOLTANSKI
Vice-Chairperson

District # 1
DARREN HORAN

District # 3
MINDY CONN

District # 4
JOHN DICK

Bid No: ITB 2023022

Name of Bid: Replacement of Building Intercom Systems at MHS & POI

Post Date: 11/9/2023

Notice Post Time: 2:45 p.m.

Q&A Response No: 2

Q1. Will the two portables at the Poinciana school required ceiling mount speakers currently not found during walkthrough on 11-7-2023?

A1. Existing speakers and call buttons are to be reused. If existing speakers are above the ceiling, relocate into drop ceiling system.

Q2. The two portables at the Poinciana school currently have two call buttons, how are where does the cables connecting these buttons terminate?

A2. All call buttons connect to the 25v speaker in the room and then homerun to the head end where they terminate to a station card.

Q3. Is there spare conduits from the Poinciana two portables to the primary facility IDF or electrical room?

A3. There is conduit running underground for the intercom cabling to the main building. It is currently holding the existing intercom wiring for the portables.

Q4. At the Marathon school, how many Primex clocks are to be replaced with Bogen clocks?

A4. None. All clocks at MHS are already Bogen clocks.

Q5. How many Bogen clocks at the Marathon school are to be placed on a wireless network system or hardwired?

A5. None- All clocks at MHS are already Bogen clocks.