


MARK T. PORTER
Superintendent of Schools



Members of the Board

District # 1
BOBBY HIGHSMITH

District # 2
ANDY GRIFFITHS
Chairman Emeritus

District # 3
ED DAVIDSON

District # 4
JOHN R. DICK
Chairman

District # 5
RONALD A. MARTIN
Vice-Chairman

Bid No: ITB 2016604
Name of Bid: KWHS Biodiesel Roof

Notice Post Date: 10/20/2015
Notice Post Time: 5:00 P.M.

Q&A No2

- 1) Scope of work (A.3) stats that an tapered insulation system must be installed, roof deck have a slope, is tapered insulation still required? **Tapered insulation is not required as roof does have a slope. Flat board insulation can be used.**
- 2) Please provide thickness or R-value required for newly installed insulation. **3"**
- 3) Please provide drawing of roof area with dimensions to verify field takeoffs and roof sections to be done. **Not our intention to provide drawings. You can provide drawing and /or square footage in your proposal so that we can confirm correct sizes. If interested in taking measurements of buildings please contact Dan Martin at 305-293-1400 Ext 53465.**
- 4) There is a rusted AC stand on building 5-511, is replacement required and should be included in base bid? **Please remove rusted a/c stand as part of base bid.**
- 5) There are abandoned electrical out lets at roof level, please verify that it is disconnected and have on electricity. Is removal required? **No electricity. We will remove abandoned electrical. Please roof over poles left behind.**
- 6) There are several abandoned curbs of the roof, are these to be left in place and re-flashed, or remove and repair the deck as follow – **Abandoned curbs should be removed according to a) below.**
 - a) Install heavy duty sheet metal cover over the opening prior to installing roof.
 - b) Repair and re-seal opening with new concrete decking prior to installing the roof
- 7) Can our kettle stay overnight at the job site and will a laydown area be provided near the job site to store additional equipment and some material? **Yes it can stay overnight. All items will need to be secured for safety and security.**